



# Construction Checklist - Safety

**Employer** \_\_\_\_\_ **Report Number:** \_\_\_\_\_

**CSHO Name** \_\_\_\_\_ **Date of inspection:** \_\_\_\_\_

**FALL PROTECTION & WALKING WORKING SURFACES**

	<b>Reference</b>	<b>YES</b>	<b>NO</b>	<b>N/A</b>
Opensided surfaces over 4' guarded by standard railing or equiv?	155-505(6)(a)	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Is fall protection used when exposed to 10' fall hazard?	155-24510	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
PFAS lifeline adjusted to keep falls less than 6 feet?	155-24510(1)(b)(vii)**	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Is fall protection work plan available and implemented?	155-24505(1)	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Wall openings <36" from floor guarded by standard railing / equiv?	155-505(5)(a)	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Floor openings (12" or more) are guarded or covered?	155-505(4)(a)	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Is warning line system set up correctly for low pitched roof?	155-24515(3) & (4)**	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Monitor system implemented correctly?	155-24521(1) – (5)**	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Leading edge control zone set up correctly?	155-24520(1)(a)-(g)**	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>

\*\*Double asterisk codes are to be cited as 155-24510

**LADDERS / STAIRWAYS / RAMPS**

	<b>Reference</b>	<b>YES</b>	<b>NO</b>	<b>N/A</b>
Stairway (temp/perm) installed on all structures 2 stories or more?	155-477(1)(c)	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Guardrail (ii) handrail (i) on stairways w/ 4 or more risers or 30"?	155-477(3)(a)(i) or (ii)	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Stair or ramp provided for break in elevation =>19"?	155-476(1)	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Ramp used for access is at least 18" wide?	155-515(1)	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Ladders extend 3 ft beyond upper landing?	876-40030	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Ladders used for purpose they were designed for?	876-40005	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Top of self supported ladder used as step?	876-40050	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Defective ladder marked and removed from service?	876-30005	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Ladder use training provided?	876-15005	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Ladders set up on unlevelled or slippery surface not secured?	876-40015	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>

**GUARDING TOOLS**

		<b>YES</b>	<b>NO</b>	<b>N/A</b>
Hand-held power circular saws properly guarded?	155-370(2)	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Table saws properly guarded? (hood, spreader, anti-kickback)	155-370(3)(a)	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Radial-arm saws properly guarded?	155-370(4)(a)	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Power miter saws properly guarded?	155-370(7)	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Muzzle safety return spring in place?	155-350(1)	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>

**SCAFFOLD scaffolding = components, scaffold = whole system**

	<b>Reference</b>	<b>YES</b>	<b>NO</b>	<b>N/A</b>
Scaffold set up by qualified competent person?	874-20004	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Scaffold work platform fully planked?	874-20008	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Scaffold provided with safe access?	874-20022	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Scaffold over 10' is fall protection provided?	874-20052	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Scaffold guardrail system meets the requirements?	874-20064	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Scaffold (legs, poles, and frames) is set up on firm footing?	874-40006	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>

**PERSONAL PROTECTIVE EQUIPMENT (PPE)**

	<b>Reference</b>	<b>YES</b>	<b>NO</b>	<b>N/A</b>
Individual hard hats available on site?	155-205(2)	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Hard hats used when exposed to flying or falling objects?	155-205(3)	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Eye protection worn? Face protection worn?	155-215(1)(a) / 350(3)	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Suitable clothing -short sleeved shirt and long pants worn?	155-200(2)	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Proper footwear worn?	155-212(1) & (3)	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Leg protection used during chainsaw usage?	155-211	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>

**ELECTRICAL**

	Reference	YES	NO	N/A
Extension cords with ground pin?	155-447(6)(f)	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Extension cords free of improper splices?	155-449(7)(b)(iii)	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Multi-outlet J-Boxes are waterproof?	155-449(1)(a)(iii)	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
GFCI or assured grounding program?	155-447(2)(a)(i)	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Strain relief device engaged on cords?	155-449(7)(b)(iv)	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>

**POWERED INDUSTRIAL TRUCKS/ELEVATED PLATFORMS**

	Reference	YES	NO	N/A
PIT designed to lift personnel on a work platform?	155-615(3)(h)(i)-(ix)	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
PIT operator trained on this equipment?	863-60005	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Elevated platform used safely? Fall Protection?	869-60040	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Did elevated platform operator survey the workplace for hazards?	869-60010	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Did elevated platform operator get required training?	869-50005	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>

**MOTOR VEHICLES ON JOBSITE**

	Reference	YES	NO	N/A
Equipment operated within 10' of power line/distribution equip.?	155-605(1)(h)	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Dump truck safe backing procedures followed?	155-610(2)(f)	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Back-up alarm on equipment operating on site? (spotter used?)	155-610(2)(e)	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>

**RELATED PROGRAM REQUIREMENTS**

	Reference	YES	NO	N/A
Is there a written APP, tailored to the address the hazards?	155-110(2)	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Does the employer conduct safety orientations?	155-110(3)	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Crew Leader-Crew Safety meeting held at beginning of job & weekly thereafter?	155-110(5)(a)	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Are safety meetings tailored to the operations?	155-110(5)(b)	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Are safety meetings topics and attendance documented?	155-110(6)(d) & (e)	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Are safety walk-around inspections conducted at the beginning of the job and weekly thereafter?	155-110(9)(a)	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Are walk-around inspections documented & available on site?	155-110(9)(b)	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>

**HAZARDOUS CHEMICAL USED ON WORKSITE**

	Reference	YES	NO	N/A
Is there a written hazard communication program and is it implemented?	800-17005	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Is there a Chemical Inventory for chemicals on-site?	800-17010	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Is there an MSDS for each hazardous product?	800-17015	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Are employees provided HAZCOM training?	800-17030	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>

**FIRST-AID**

	Reference	YES	NO	N/A
Are first-aid supplies available on-site?	800-15020	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Is there a first-aid certified person or persons on site?	155-120(1)	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Is the crew leader or supervisor first aid certified?	155-120(2)	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>

**HOUSEKEEPING & SANITATION**

	Reference	YES	NO	N/A
Is proper housekeeping maintained at the jobsite?	155-020(1) - (12)	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
*Adequate supply of potable water provided?	155-140(1)(a)	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
*Toilets provided and maintained at jobsite?	155-140(4)(b) & (4)(d)	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>

Does not apply to mobile crews or normally unattended work locations per WAC 296-155-140 (1) (g) & (h) . Mobile crew is defined as "A work crew that routinely moves to a different work location periodically. Normally a mobile crew is not at the same location all day."

<sup>1</sup> This emphasis checklist outlines fundamental requirements and is not inclusive of all safety and health requirements for employers in the construction industry. Other requirements can be found in the Washington Administrative Code (WAC) Chapters 296-24, 296-62, 296-155, 296-800, 296-863, 296-869, 296-874, and 296-876. Information relevant to these requirements or further assistance can be found on the agency website located at: <http://www.lni.wa.gov/safety>